



2015 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 4560025 NAME: Indian Lake Borough Water Works

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Dean J. Snyder at 814-267-4614. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Wednesday of each month at 7:00 PM at the Indian Lake Borough Building.

SOURCE(S) OF WATER:

Our water source(s) is/are: (Name-Type-Location)

From ground water for Well #2, which is located on West Shore Trail between Potomac Lane and Algonquin and from ground water for Well 99-1, which is located at the bottom of West Shore Trail Extension. The aquifers, which supplies these wells are in the Glenshaw Formation. West Shore Trail Extension to Indian Lake Drive are served by Well #2. Indian Lake Drive to Causeway Drive are served by Well 99-1.

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2014. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Well 99-1 Barium	2	2	.222	.19	MG/L	3-18-15	N	Discharge of drilling wastes; Discharge from metal refineries; erosion of natural deposits
Well #2 Barium	2	2	.102	.11	MG/L	3-18-15	N	Discharge of drilling wastes; Discharge from metal refineries; erosion of natural deposits
Trihalomethanes	0.080	0.080	.0098	.0098	MG/L	7-14-14	N	By-product of drinking water chlorination

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Well 99-1 Chlorine	0.4	0.41	0.41 to 1.69	ppm	1-02-15	N	Water additive used to control microbes.
Well 2 Chlorine	0.4	0.41	0.41 to 1.63	ppm	6-12-15	N	Water additive used to control microbes.

Lead and Copper							
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	0	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	.366	ppm	0	N	Corrosion of household plumbing.

Microbial						
Contaminant	MCL	MCLG	Highest # or % of Positive Samples	Violation Y/N	Sources of Contamination	
Total Coliform Bacteria	For systems that collect <40 samples/month: <ul style="list-style-type: none"> • More than 1 positive monthly sample For systems that collect ≥ 40 samples/month: <ul style="list-style-type: none"> • 5% of monthly samples are positive 	0	0	N	Naturally present in the environment.	
Fecal Coliform Bacteria or <i>E. coli</i>	0	0	0	N	Human and animal fecal waste	

Turbidity						
Contaminant	MCL	MCLG	Level Detected	Sample Date	Violation Y/N	Source of Contamination
Turbidity	TT=1 NTU for a single measurement	0	0	0	0	Soil runoff.
	TT= at least 95% of monthly samples ≤ 0.3 NTU					

<i>Total Organic Carbon (TOC)</i>					
Contaminant	Range of % Removal Required	Range of percent removal achieved	Number of quarters out of compliance	Violation Y/N	Sources of Contamination
TOC	N/A				Naturally present in the environment.

HEALTH EFFECTS:

N/A

OTHER VIOLATIONS:

N/A

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

